

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	260036361
Drinking-Water System Name:	Countryside Camp & Conference Centre Well Supply
Drinking-Water System Owner:	Countryside Camp & Conference Centre Association
Drinking-Water System Category:	Small Non-Municipal Non-Residential
Period being reported:	April 1, 2025, to March 31, 2026

<u><i>Complete if your Category is Large Municipal Residential or Small Municipal Residential</i></u>	<u><i>Complete for all other Categories.</i></u>
<p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Countryside Camp & Conference Centre 1985 Beke Rd. RR #4 Cambridge, ON N1R 5S5 </div>	<p>Number of Designated Facilities served:</p> <div style="border: 1px solid black; width: 100px; text-align: center; margin: 5px;">1</div> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [x] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; width: 100px; text-align: center; margin: 5px;">N/A</div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [x] No []</p>

List Drinking-Water Systems, which receive all of their drinking water from your system:

Countryside Camp & Conference Centre

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [x]

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper

Drinking-Water Systems Regulation O. Reg. 170/03

- Public access/notice via Public Request**
- Public access/notice via a Public Library**
- Public access/notice via other method** _____

Describe your Drinking-Water System

Two separate wells and treatment systems feed a distribution system throughout the facility.

List all water treatment chemicals used over this reporting period

Chlorine / Water softener / We do not add Floride to our DWS

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Describe

We followed all recommended regular maintenance schedules for equipment and filtering systems as required in our DWS operations manual. We were fully open for the rental ministry season, and our summer camp program was able to operate fully in 2025 under our Safety Plan.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
31Jan2022 Distribution AWQI 157755	Sodium (Na)	126	mg/l	Re-sampling was required of the distribution system and the result was 44.9, still higher than standard Na result. Required to Post Signs in all Kitchen and Lodge areas Notifying guests on a Sodium restrictive diet	15Feb2022

Microbiological testing done under section 8-2 during this reporting period

	Number of Samples	Range of E.Coli Or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of HPC Samples Or Background Colony Counts	Range of HPC Results (#-#) Or Background Colony Counts
Raw	22	0-0	0-0	0	0
Treated	8	0-0	0-0	0	0
Distribution	13	0-0	0-0	11	0-13

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity	365	0.14-0.92
Chlorine	365	0.01-2.57
Chlorine Residual Distribution System	365	0.13-2.69
Fluoride (If the DWS provides fluoridation)		

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Location	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Shop Well	09DEC22	<0.60	ug/l	6
Arsenic	Shop Well	09DEC22	<1.0	ug/l	25
Barium	Shop Well	09DEC22	<10	ug/l	1000
Boron	Shop Well	09DEC22	<50	ug/l	5000
Cadmium	Shop Well	09DEC22	<0.10	ug/l	5
Chromium	Shop Well	09DEC22	<1.0	ug/l	50
Lead	Distribution	30JAN25	<1.0	ug/l	10
Mercury	Shop Well	09DEC22	<0.100	ug/l	1
Selenium	Shop Well	09DEC22	<1.0	ug/l	10
Sodium	Shop Well	31JAN22	126	mg/l	20
Sodium	Shalom House Well	04JUN25	126	mg/l	20

Uranium	Shop Well	09DEC22	<2.0	ug/l	20
Fluoride	Distribution	31JAN22	0.62	mg/l	1.5
Nitrite	E1 Shop	01MAY25	<0.010	mg/l	1
Nitrate	E1 Shop	01MAY25	<0.020	mg/l	10
Nitrite	E2 Shalom	01MAY25	<0.010	mg/l	1
Nitrate	E2 Shalom	01MAY25	<0.020	mg/l	10
Nitrite	E1 Shop	26AUG25	<0.020	mg/l	1
Nitrate	E1 Shop	26AUG25	<0.040	mg/l	10
Nitrite	E2 Shalom	26AUG25	<0.010	mg/l	1
Nitrate	E2 Shalom	26AUG25	<0.020	mg/l	10
Nitrite	E1 Shop	23OCT25	<0.010	mg/l	1
Nitrate	E1 Shop	23OCT25	<0.020	mg/l	10
Nitrite	E2 Shalom	23OCT25	<0.010	mg/l	1
Nitrate	E2 Shalom	23OCT25	<0.020	mg/l	10
Nitrite	E1 Shop	16JAN26	<0.010	mg/l	1
Nitrate	E1 Shop	16JAN26	<0.020	mg/l	10
Nitrite	E2 Shalom	16JAN26	<0.010	mg/l	1
Nitrate	E2 Shalom	16JAN26	<0.020	mg/l	10

These are the results from the Shop Well Testing in 2022
Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	09DEC22	<0.10	ug/l	0.1
Atrazine	09DEC22	<0.10	ug/l	0.1
Atrazine & Metabolites	09DEC22	<0.20	ug/l	0.2
Atrazine -desethyl	09DEC22	<0.10	ug/l	0.1
Azinphos-methyl	09DEC22	<0.10	ug/l	0.1
Benzene	09DEC22	<0.50	ug/l	0.5
Benzo(a)pyrene	09DEC22	<0.0050	ug/l	0.005
Bromoxynil	09DEC22	<0.20	ug/l	0.2
Carbaryl	09DEC22	<0.20	ug/l	0.2
Carbofuran	09DEC22	<0.20	ug/l	0.2
Carbon Tetrachloride	09DEC22	<0.20	ug/l	0.2
Chlorpyrifos	09DEC22	<0.10	ug/l	0.1
Diazinon	09DEC22	<0.10	ug/l	0.1
Dicamba	09DEC22	<0.20	ug/l	0.2
1,2-Dichlorobenzene	09DEC22	<0.50	ug/l	0.5
1,4-Dichlorobenzene	09DEC22	<0.50	ug/l	0.5

1,2-Dichloroethane	09DEC22	<0.50	ug/l	0.5
1,1-Dichloroethylene (vinylidene chloride)	09DEC22	<0.50	ug/l	0.5
Dichloromethane	09DEC22	<0.50	ug/l	0.5
2-4 Dichlorophenol	09DEC22	<0.20	ug/l	0.2
Diclofop-methyl	09DEC22	<0.20	ug/l	0.2
Dimethoate	09DEC22	<0.10	ug/l	0.1
Diquat	09DEC22	<1.0	ug/l	1
Diuron	09DEC22	<1.0	ug/l	1
Ethylbenzene	09DEC22	<0.50	ug/l	0.5
Fluorobiphenyl	09DEC22	87.8	%	40-130
Glyphosate	09DEC22	<5.0	ug/l	5
Malathion	09DEC22	<0.10	ug/l	0.1
MCPA	09DEC22	<0.20	ug/l	0.2
Diclofop-methyl	09DEC22	<0.20	ug/l	0.2
Metolachlor	09DEC22	<0.10	ug/l	0.1
Metribuzin	09DEC22	<0.10	ug/l	0.1
Monochlorobenzene	09DEC22	<0.50	ug/l	0.5
Oxychlorobenzene	09DEC22	<0.0080	ug/l	0.0080
Paraquat	09DEC22	<1.0	ug/l	1
Phorate	09DEC22	<0.10	ug/l	0.1
Pentachlorophenol	09DEC22	<0.50	ug/l	0.5
Picloram	09DEC22	<0.20	ug/l	0.2
Polychlorinated Biphenyls (PCBs)	09DEC22	<0.035	ug/l	0.035
Prometryne	09DEC22	<0.10	ug/l	0.1
Simazine	09DEC22	<0.10	ug/l	0.1
Terbufos	09DEC22	<0.20	ug/l	0.2
Tetrachloroethylene	09DEC22	<0.50	ug/l	0.5
1,1 Dichloroethylene	09DEC22	<0.50	ug/l	0.5
Triallate	09DEC22	<0.10	ug/l	0.1
Toluene	09DEC22	<0.50	ug/l	0.5
Trichloroethylene	09DEC22	<0.50	ug/l	0.5
2,3,4,6-Tetrachlorophenol	09DEC22	<0.50	ug/l	0.5
2,4,6-Trichlorophenol	09DEC22	<0.50	ug/l	0.5
2,4-D	09DEC22	<0.20	ug/l	0.2
Trifluralin	09DEC22	<0.10	ug/l	0.1
Vinyl Chloride	09DEC22	<0.20	ug/l	0.2
Xylenes (Total)	09DEC22	<1.5	ug/l	1.5

These are the results of the Shalom House Well Testing in 2025.

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Location	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony		29APR24	<0.60	ug/l	6
Arsenic		29APR24	4.6	ug/l	25
Barium		29APR24	<10	ug/l	1000
Boron		29APR24	70	ug/l	5000
Cadmium		29APR24	<0.10	ug/l	5
Chromium		29APR24	<1.0	ug/l	50
Mercury		29APR24	<0.100	ug/l	1
Selenium		29APR24	<1.0	ug/l	50
Uranium		29APR24	<2.0	ug/l	20

Summary of Volatile Organic Compounds sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Acetone	08MAY24	<20	ug/l	20
Alachlor	22MAY24	<0.05	ug/l	5
Aroclor 1242;1254;1260	22MAY24	<0.020	ug/l	.02
Atrazine, ; Atrazine Desethyl	22MAY24	<0.10	ug/l	
Atrazine + Metabolites	22MAY24	<0.14	ug/l	5
Azinphos-methyl	08MAY19	<0.10	ug/l	20
Benzene	08MAY24	<0.50	ug/l	1
Benzo(a)pyrene	08MAY19	<0.0050	ug/l	.01
Bromodichloromethane	08MAY24	<0.50	ug/l	0.50
Bromoform	08MAY24	<0.50	ug/l	0.50
Bromomethane	08MAY24	<0.50	ug/l	0.50
Bromoxynil	09MAY24	<0.05	ug/l	5
Carbaryl	08MAY19	<0.20	ug/l	90
Carbofuran	08MAY19	<0.20	ug/l	90
Carbon Tetrachloride	07MAY19	<0.20	ug/l	2
Chlorpyrifos	08MAY19	<0.10	ug/l	90
Diazinon	08MAY19	<0.10	ug/l	20
Dicamba	22MAY24	<0.10	ug/l	120
1,2-Dichlorobenzene	07MAY19	<0.50	ug/l	200
1,4-Dichlorobenzene	07MAY19	<0.50	ug/l	5
Dichlorodiphenyltrichloroethane (DDT) + metabolites	07MAY19	<0.10	ug/l	
1,2-Dichloroethane	07MAY19	<0.50	ug/l	5
1,1-Dichloroethylene (vinylidene chloride)	07MAY19	<0.50	ug/l	14

Dichloromethane	07MAY19	<5.0	ug/l	50
2-4 Dichlorophenol	07MAY19	<0.30	ug/l	900
2,4-Dichlorophenoxy acetic acid (2,4-D)	22MAY24	<0.05	ug/l	50-130
Diclofop-methyl	22MAY24	<0.10	ug/l	9
Dimethoate	08MAY19	<0.10	ug/l	20
Diquat	22MAY24	<1.0	ug/l	70
Diuron	22MAY24	<0.05	ug/l	150
Ethylbenzene	07MAY19	<0.50	ug/l	140
Fluorobiphenyl	08MAY19	92	ug/l	40-130
Glyphosate	05MAY19	<5.0	ug/l	280
Malathion	08MAY19	<0.10	ug/l	190
MCPA	09MAY19	<0.20	ug/l	100
Metolachlor	08MAY19	<0.10	ug/l	50
Metribuzin	08MAY19	<0.10	ug/l	80
Monochlorobenzene	07MAY19	<0.50	ug/l	80
Oxychlorane	07MAY19	<0.10	ug/l	
Paraquat	05MAY19	<1.0	ug/l	10
Pentachlorophenol	07MAY19	<0.50	ug/l	60
Phorate	08MAY19	<0.10	ug/l	2
Picloram	09MAY19	<0.20	ug/l	190
Polychlorinated Biphenyls(PCB)	08MAY19	<0.035	ug/l	3
Prometryne	08MAY19	<0.10	ug/l	1
Simazine	08MAY19	<0.10	ug/l	10
Terbufos	08MAY19	<0.20	ug/l	1
2,3,4,6 Tetrachlorophenol	07MAY19	<0.50	ug/l	100
Tetrachloroethylene	07MAY19	<0.50	ug/l	10
Toluene	07MAY19	<0.50	ug/l	60
Triallate	08MAY19	<0.10	ug/l	230
Trichloroethylene	07MAY19	<0.50	ug/l	5
2,4,6-Trichlorophenol	07MAY19	<0.50	ug/l	5
2,4-D	09MAY19	<0.20	ug/l	100
Trifluralin	09MAY19	<0.10	ug/l	45
Vinyl Chloride	07MAY19	<0.20	ug/l	1
Xylenes (Total)	07MAY19	<1.5	ug/l	90

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non municipal year round residential, large non municipal non residential)

